

**DRINKING WATER NOTICE**  
**Vermilion City**  
**Significant Deficiency/Treatment Technique Requirements**

**What happened?**

The Ohio EPA has identified significant deficiencies associated with the water treatment system. In an April 11, 2018 letter, Ohio EPA required Vermilion City to replace the tower stem and expansion joint by September 23, 2018. This work was not completed within the required timeframe. An inspection report detailing the results of the clearwell #1 and #2 inspection was not submitted as required by October 31, 2018. This report was submitted on November 1, 2018.

**What should I do?**

- **You do not need to boil the water or take other corrective actions regarding this violation.**

**What does this mean?**

- This situation does not require that you take immediate action. If it had been, you would have been notified immediately.
- Adequate quantities of safe drinking water are necessary for maintaining public health protection.

**What is being done?**

- We are investigating and we are taking the necessary steps to correct the problem as soon as possible.

For more information regarding this violation notice or for any other questions regarding your drinking water, please contact:

**Eugene Baker at office: 440-204-2450 or cell: 440-320-4490**

By Mail: Eugene Baker Water Plant Superintendent  
5511 Liberty Ave.  
Vermilion, OH 44089

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID#: OH2201511

Date distributed: \_\_\_\_\_

Tier 2: Treatment Technique Violation (Significant Deficiency type 45)  
(Please retain this copy for your records.)

C:\Users\WAF\Downloads\Drinking Water Notice.docx